



**NOTES:**

1. This standard applies to apartment and office complexes; 3 or more buildings or composed of 6 or more units.
2. Sign is to show entire complex with roads, entrances, parking areas, building with apartment or office numbers, sign location and any fire fighting facilities. Hydrants shall be indicated by the symbol .
3. Illumination to be sufficient to light entire sign.
4. Sign shall be visible from normal access road. Care should be taken that the sign does not interfere with visibility of traffic.

5. Construction to be dimensioned as shown for pressure treated or redwood 4x6's and exterior grade, exterior exterior glued 1/2" plywood (nominal 2" thick by 12" width redwood may be used). All paint to be exterior enamel. Apartment or office numbers, buildings and paved areas to be contrasting colors. Street address and apartment or office numbers to be 2" high.
6. Footing concrete shall be a minimum of 2000 psi at 28 days.
7. Refer to Uniform Fire Code 10-208 and 10-301 for sign requirements.