



TYPE A

2.5' TO 5' DROP

NOTES

1. MANHOLE SHALL BE CONSTRUCTED IN ACCORDANCE WITH CITY STANDARD DRAWING S-1 & S-2.
2. USE OF DROP MANHOLES SHALL BE DISCOURAGED AND ALLOWED ONLY UPON SPECIAL AUTHORIZATION OF THE CITY ENGINEER BASED UPON THE FOLLOWING CRITERIA:
 - A. USED FOR 6" AND 8" DIA. LATERAL LINES ONLY
 - B. WHEN DESIGN VELOCITIES WILL EXCEED 7.5 FPS
 - C. WHENEVER THE DIFFERENCE BETWEEN THE SOFFIT OF THE MAIN LINE AND THE SOFFIT OF THE LATERAL LINE IS TWO FEET OR GREATER
3. ALL CONCRETE SHALL BE CLASS "A".

DROP MANHOLE
TYPE "A"

REF. & REV.
MARCH 2005
MAY 2007

CITY OF MADERA

S-4