



NOTE:

1. GOOD FOR INSTALLATIONS WITH 3' MIN. AND 12' MAX. COVER OTHERWISE SEE DWG. S-5, AT OTHER DEPTHS, REQUIREMENT FOR CONCRETE INCASEMENT MAY BE WAIVED SUBJECT TO CITY ENGINEER APPROVAL WHEN PLANS ARE SUBMITTED BY A REGISTERED CIVIL ENGINEER INDICATING NO NEED FOR ADDITIONAL SUPPORT.
2. PVC GRAVITY SEWER PIPE SHALL CONFORM TO STANDARD SPECIFICATIONS.
3. (*) INDICATES RELATIVE COMPACTION.
4. ALL TRENCHES SHALL HAVE COMPACTION TESTS AT LOCATIONS DETERMINED BY ENGINEERING DEPARTMENT.
5. PAYMENT FOR COMPACTION TEST WILL BE THE RESPONSIBILITY OF THE CONTRACTOR.

Dips in Sewer Pipe cannot exceed the following:		
8"	-	3/4"
10"	-	1"
12"	-	18" - 1 1/4"
24"	-	36" - 1 1/2"

PIPE BEDDING & TRENCH BACKFILL

REF. & REV.
MARCH 2005
DEC. 2009

CITY OF MADERA

S-10