

## **SECTION 20 - STORM DRAINAGE PIPING AND STRUCTURES**

### **20-1 GENERAL**

All storm drainage facilities, whether temporary or permanent, shall be installed in accordance with these Standard Specifications and Standard Drawings.

Trench excavation and backfill, in all public easements and public rights-of-way, shall be constructed in accordance with Section 16 of these Standard Specifications.

### **20-2 USE OF PLASTIC PIPE**

Plastic pipe for storm drainage facilities shall conform with Section 17 of these Standard Specifications, with the following conditions:

1. The pipe size is limited to 24 inches in diameter, and
2. In areas where the hydraulic grade line is above the soffit of the storm drain pipe, only watertight joints are allowed and shall comply with Section 61 of the State Standard Specifications.