



LOCKJAW SECURITY LID
www.sipracorp.com

CHRISTY BOX	DIMENSIONS	LOCKJAW LID PART NUMBER
N9	10" X 15 1/8"	ELJ09
N16	10-1/2" X 20-5/8"	ELJ16
N30	13-3/4" X 23-1/8"	LOCKJAW 30
N36	17-1/2" X 30-1/2"	LOCKJAW 36-2 OR LOCKJAW 36-4
N48 (6-JAW) 3-PIECE UNIT	30-1/8" X 48-1/4"	LOCKJAW 48

GENERAL NOTES:

- PULL BOXES SHALL NOT BE INSTALLED OVER JOINT TRENCHES, IN DRIVEWAYS OR IN ROADWAYS.
- PULL BOX SPACING SHALL NOT EXCEED 200' AND SHALL BE REQUIRED AT ALL CONDUIT CHANGES OF DIRECTION.
- REMOVE LIDS BEFORE POURING CONCRETE AROUND PULL BOXES.
- PULL BOXES SHALL BE GROUTED PRIOR TO INSTALLATION OF CONDUCTORS, SLOPED TOWARD THE DRAIN HOLE. PLACE A LAYER OF ROOFING PAPER BETWEEN THE CRUSHED ROCK AND THE GROUT.
- WRAP PULL BOX WITH ROOFING PAPER BEFORE BACKFILLING.
- INSTALL A ONE-FOOT RING OF CONCRETE, FOUR INCHES DEEP, AROUND THE WRAPPED PULL BOXES INSTALLED IN DIRT OR GRASS AREAS, SLOPED TO DRAIN AWAY FROM THE PULL BOX.
- PULL BOXES SHALL BE LEVELED TO FINISH GRADE
- LOCKJAW SECURITY LIDS SHALL BE INSTALLED AS DIRECTED BY THE CITY ENGINEER.
- LOCKJAW LIDS MUST BE GROUNDED AS PER MANUFACTURER RECOMMENDATIONS.
- COORDINATE WITH THE PUBLIC WORKS DEPT. ON LOCKJAW LID INSTALLATIONS, NEW OR EXISTING.
- ALL PULL BOXES SHALL BE INSTALLED WITH EXTENSIONS.
- SEE ST-24 FOR ADDITIONAL INFORMATION.

STREETLIGHT
 CONCRETE PULL BOX

REF. & REV.
 AUG. 2008
 OCT. 2009
 JULY 2013
 SEPT 2015

CITY OF MADERA

ST-22