



- NOTE:
1. ALL FITTINGS SHALL BE SECURED WITH RETAINING GLANDS, HARNESSES OR TIE-RODS AS APPLICABLE.
  2. PLACE VALVES AND BLOW-OFFS OUTSIDE SIDEWALK AND DRIVEWAY AREAS.
  3. ALL PUMP DISCHARGES SHALL BE FLANGED STEEL
  4. ALL RISERS SHALL BE FLANGED, 6" DIAMETER.

BLOW-OFF SCHEDULE	
PIPE SIZE	
MAIN	BLOW-OFF
6"	4"
8"	4"
10"	4"
12"	6"
14"	6"
16"	6"

# BLOW-OFF ASSEMBLY TYPE B

REF. & REV.  
MARCH 2005

CITY OF MADERA

W-28