

Bacteriological Water Analysis

City of Madera - Water Division
1030 South Gateway Drive
Madera CA 93637
00-0023133 52

Routine

Lab No.: 24C0368

Sampled By: Bar

Requested By:

Submitted Date: 03/12/24

Reported Date: 03/13/24

Project: Bacti System 2010002-DST-BACT

Crop ID:


E-mail: jbotwright@madera.gov;mmendoza@madera.gov

Copy To:

		Date Sampled	Time Sampled	Residual Chlorine mg/L	Rec'd Temp °C	Date Started	Time Started	Total Coliform per 100 mL	E-Coli per 100 mL	Meter Reading Field
1	Sample Station #2	03/12/24	9:50	0.34	0.3	3/12/2024	16:08	Absent	Absent	
2	Sample Station #3	03/12/24	8:50	0.35	1.4	3/12/2024	16:08	Absent	Absent	
3	Sample Station #7	03/12/24	8:40	0.26	0.1	3/12/2024	16:08	Absent	Absent	
4	Sample Station #8	03/12/24	7:10	0.38	1.1	3/12/2024	16:08	Absent	Absent	
5	Sample Station #11	03/12/24	9:10	0.40	1.1	3/12/2024	16:08	Absent	Absent	
6	Sample Station #13	03/12/24	10:20	0.37	0.6	3/12/2024	16:08	Absent	Absent	
7	Sample Station #19	03/12/24	10:00	0.39	0.9	3/12/2024	16:08	Absent	Absent	
8	Sample Station #20	03/12/24	9:00	0.34	1.4	3/12/2024	16:08	Absent	Absent	
9	Sample Station #22	03/12/24	7:00	0.32	3.1	3/12/2024	16:08	Absent	Absent	
10	Sample Station #24	03/12/24	9:20	0.29	1.3	3/12/2024	16:08	Absent	Absent	
11	Sample Station #26	03/12/24	10:40	0.36	0.5	3/12/2024	16:08	Absent	Absent	
12	Sample Station #27	03/12/24	11:00	0.37	0.6	3/12/2024	16:08	Absent	Absent	
13	Sample Station #28	03/12/24	8:30	0.57	2.4	3/12/2024	16:08	Absent	Absent	
14	Sample Station #29	03/12/24	9:40	0.23	0.8	3/12/2024	16:08	Absent	Absent	
15	Sample Station #30	03/12/24	7:30	0.38	2.0	3/12/2024	16:08	Absent	Absent	
16	Sample Station #31	03/12/24	7:20	0.38	1.9	3/12/2024	16:08	Absent	Absent	
17	Sample Station #32	03/12/24	10:10	0.38	0.5	3/12/2024	16:08	Absent	Absent	
18	Sample Station #36	03/12/24	8:10	0.46	1.1	3/12/2024	16:08	Absent	Absent	
19	Water Tower	03/12/24	6:30	0.34	2.1	3/12/2024	16:08	Absent	Absent	

* = Field CL₂ not taken.

Records retained for 5 yrs.

Approved By: 
Laboratory Director/Technical Manager
ELAP Certification #1595
A2LA Certification #6440.02

Bacteriological Water Analysis

City of Madera - Water Division
1030 South Gateway Drive
Madera CA 93637
00-0023133 52

Special

Lab No.: 24C0665
Sampled By: Martin M
Requested By:
Submitted Date: 03/19/24
Reported Date: 03/20/24
Project: Bacti System
Crop ID:

E-mail: ebrooks@madera.gov
Copy To: jbotwright@madera.gov;mmendoza@madera.gov

		Date Sampled	Time Sampled	Residual Chlorine mg/L	Rec'd Temp °C	Date Started	Time Started	Total Coliform per 100 mL	E-Coli per 100 mL	Meter Reading Field
1	Water Tower	03/19/24	6:20	0.31	2.3	3/19/2024	15:33	Absent	Absent	

* = Field CL₂ not taken.
Records retained for 5 yrs.

Approved By: *Scott M. Friedman*
Laboratory Director\Technical Manager
ELAP Certification #1595
A2LA Certification #6440.02